BR - 47 | 30-4-14

CIVILTECH LABS

TEST REPORT ON CEMENT

Name of the Client	AEE, Hebbal Sub Division, BBMP
Name of Work	Construction of drains and culverts in Doddappaiah Layout in Ward No.18
Agency Name	Sri. B. H. Harish

Tests on Cement	Test Date	Tests	Test Method As Per IS & Apparatus		Results		Requirements As Per IS 8112 1989	Remarks
			IS Code	Method	Value	Unit		
	20/03/2014	Initial Setting Time	IS-4031 (Part-5) 1988	VICAT	52	min	Not Less Than 30 Minutes	Satisfies Requirement
		Final Setting Time	IS-4031 (Part-5) 1988	VICAT	482	min	Not More Than 600 Minutes	Satisfies Requirement
		Soundness	IS-4031 (Part-3) 1988	LE-CHATELIER	3	mm	Not More Than 10 mm	Satisfies Requirement

Note:

1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the Client

CIVIL TECH LABS
5,I Floor, I Cross
Srinivasa Colony, Missi ad,
BANGALORE - 56

AE-18

Lab Incharge
Civil Tech Labs

CIVILTECH LABS

TEST REPORT ON COARSE AGGREGATES 40mm ↓ Graded Ref:IS:383/2386

Name of the Client	AEE, Hebbal Sub Division, BBMP
Name of Work	Construction of drains and culverts in Doddappaiah Layout in Ward No.18
Agency Name	Sri. B. H. Harish

Sample	Date of Testing	Specific Gravity	Absorption in %	IS Sieve designation (mm)	Sieve Analysis (% Passing IS Sieve)	Grading Requirement As Per IS 383-1970	Remarks
40mm Down Graded	20/03/2014	2.67	0.29	80	100	100	Satisfies The Requirements
				40	97	95-100	
				20	59	30-70	
				10	21	10-35	
				4.75	3	0-5	

Note:

1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the client.

CIVIL TECH LABS
5,I Floor, I Cross,
Srinivasa Colony, Mission Road,
BANGALORE - 560 027

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

AE-18

CIVILTECH LABS

TEST REPORT ON FINE AGGREGATES Ref:IS:383/2386

Name of the Client	AEE, Hebbal Sub Division, BBMP
Name of Work	Construction of drains and culverts in Doddappaiah Layout in Ward No.18
Agency Name	Sri. B. H. Harish

Sample	Date of Testing	Specific Gravity As Per IS: 2720 Part 3 - 1970	IS Sieve designation (mm)	Sieve Analysis (% Passing IS Sieve)	Grading Requirement As Per IS 383-1970				Grading Zone
					ZONE-I	ZONE-II	ZONE-III	ZONE-IV	
Fine Aggregates	20/03/2014	2.57	10	100	100	100	100	100	II
			4.75	99	90-100	90-100	90-100	95-100	
			2.36	83	60-95	75-100	85-100	95-100	
			1.18	76	30-70	55-90	75-100	90-100	
			0.6	42	15-34	35-59	60-79	80-100	
			0.3	19	5-20	8-30	12-40	15-50	
			0.15	8	0-10	0-10	0-10	0-15	

Note:

1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the client.

CIVIL TECH LABS
#51, 1st Floor, I Cross, Road,
Srinivasa Colony, Mission Road,
BANGALORE - 560 027.

Lab Incharge
Civil Tech Labs

AE-16

CIVIL TECH LABS

TEST REPORT ON CONCRETE CUBES

Name of the Client	AEE, Hebbal Sub Division, BBMP
Project	Construction of drains and culverts in Doddappaiah Layout in Ward No.18
Agency	Sri. B. H. Harish
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 Sq.mm
Technical Reference	IS: 516-1959(Reaffirmed 2004)

Sl.No	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/Sq.mm)	Avg Compressive Strength (N/Sq.mm)
1	CC Work (Drain)	26/03/2014	23/04/2014	28	8.13	480	21.33	21.33
2					8.16	505	22.44	
3					8.15	495	22.00	

Note:

1 The results relate only to the items tested.
2 Report shall not be reproduced except in full, without the written approval of the lab.
3 Any correction invalidates this report.
4 The results are based on the test conducted on samples supplied by the client.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
#5,I Floor, I Cross,
Srinivasa Colony, Mission Road,
BANGALORE - 560 027.

4E-18